

ř

	Republic of the Philippines ILOILO SCIENCE AND TECHNOLOGY UNIVERSITY	Department:	BIDS AND AWARDS COMMITTEE
	La Paz, Iloilo City	Document Code:	QF-BAC-02
	CANVASS PAPER	Rev. No.:	03
		Effective Date:	August 3, 2015

	inquiries, please call a	Dr. Corazon C. Corbal				
Ann Lovelle D.) Faja / Lester John Rotersos Printed Name and Signature			Chairman Bids and Awards Committee			
elivery p	period upon receipt of		proved Budget: (Php)		Php 84,200.00	
item No.	Product Category	ITEM	Quantity	Unit	Unit Cost	
	Flounci Calegory	Description/Specifications		+ +		
1	Split-type Airconditioning unit	Split-type Airconditioning unit (P84,200)/unit	1	unit		
		Mounting type (indoor): floor stading				
	, 	Tonnage capacity: 3.0 TR				
		Rated cooling capacity: (BTUh) 36,000			=	
		Rated cooling capacity: (KJ/h) 37,980				
		Power consumption 3,400W				
•		Running current 15,90A				
		EER (BTU/h-W) 10.60				
		EER (Kj/hr) 11.20				
		Indoor sound level: (low cool) 50dBA				
		Air4 flow 1,500/882 CMH/CFM				
		Pipe size (liquid/gas) 3/8 & 3/4in V/Hz o				
		Refrigerant type: R22				
		Operation: LCD remote				
		Compressor type: high EER rotary				
		Filter tye:Anti-Dust/Catalyst or equivalent				
		Control type : Non-Inverter				
		With installation	<u> </u>	 		
		One year warranty on parts and services				
		x-x-x-x-x-x-x-x-x-x-x-x-x-x-x-x-x-x-x-				
		For Official use of the College of Engineering 8 Architecture Dept.				
	ŀ					