



Section VII. Technical Specifications

ITEM NO.	SPECIFICATION		STATEMENT OF COMPLIANCE			
	ABC (P 750,000.00)		[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution.]			
Procurement of Aircon Equipment for Library Fund 164						
	Specification		UNIT	QTY	BRAND	Statement of Compliance
1	Aircon	Aircon- Standard Floor Mounted 5.0 TR Capacity	unit	5		
		Cooling: 60,000 BTU/h ; 63,300 kJ/hr Power Consumption: 5,800 W Running Current: 17.5 A EER: 10.3 BTU/h-W ; 10.9 kJ/hr-W Indoor Sound Level (Low Cool) 52 dBA Airflow: 2,700/1,589 CMH/CHM Pipe size (Liquid/Gas) 1/2 & 7/8 In Volts/Hz/Phase : 208- 230/60/3 Refrigerant: R22 Unit Dimension (mm) Indoor Unit: WxDxH (mm) 610x385x1,877 Outdoo Unit: WxHxD (mm) 810x810x727 Carton Dimension Indoor Unit: WxDxH 680x499x1,935 Outdoo Unit: WxHxD 865x865x770 Max. Refrigerant Pipe Length (m) 30 Max. Difference in Level (m) 8 Operating Temperature °C : 17-30 Ambient Temperature °C : 18-43				
		Warranty 1 year				
		Delivery Period 30 calendar days				

