



Republic of the Philippines  
**ILOILO SCIENCE AND TECHNOLOGY UNIVERSITY**  
 La Paz, Iloilo City  
 • Trunkline: (033)320-7190 • Telefax: (033)329-4274  
 • Website: [www.isatu.edu.ph](http://www.isatu.edu.ph)



## Section VII. Technical Specifications

ITEM NO.	SPECIFICATION	STATEMENT OF COMPLIANCE
	ABC ( P 742,687.00)	[Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidder's statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post-qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution.]

### Procurement for Electrical Supplies Fund 101

ITEM NO.	Specification	UNIT	QTY	BRAND	Statement of Compliance
1	Conductor 2 sets (3-125mm <sup>2</sup> ) COPPER THW-2 INSULATED MAIN FEEDER CONDUCTOR	LM	65		
2	Raceway Hot depped galvanized cable ladder with supports and brackets, bonding grounding, 300mm width x 50mm side height x 200mm RUNG spaced on center	LM	60		
3	Termination Termination of feeder conductors at both Ends (Service Entrance, Enclosed C.B., and Tapping Point), complete with connectors and Accessories	LOT	1		
4	Circuit Breaker Enclosed Circuit breaker, 500A, 3P, 250V, 60HZ, wall mounted	EA	1		
5	Testing Testing and commissioning of feeder conductor and power supply	Lot	1		
	Delivery Period 60 calendar days				